



Luminaire Schedule							
Symbol	Qty	Label	Arrangement	LLF	Description	Lum. Watts	Lum. Lumens
[Symbol]	5	A	SINGLE	0.900	RAR2-320L-165-3K7-4W-U	153.6	20138
[Symbol]	4	B2	BACK-BACK	0.900	RAR2-320L-165-3K7-4W-U	153.6	20138
[Symbol]	8	C-S	SINGLE	0.900	RAR-2-320L-165-4K7-BC	154.2	11922
[Symbol]	10	D	SINGLE	0.900	RWL2-160L-155-4K7-4-U	156.8	19336
[Symbol]	4	D2	SINGLE	0.900	RWL2-160L-50-4K7-T2-U	54	7710
[Symbol]	2	E	SINGLE	0.900	RAR2-320L-110-4K7-T2-U	100.3	15213
[Symbol]	5	F	SINGLE	0.900	RAR-2-320L-140-4K7-4-BC	133	10680

Calculation Summary						
Label	CalcType	Units	Avg	Max	Min	Avg/Min
ENTRY DRIVE	Illuminance	Fc	1.84	5.6	0.0	N.A.
LOADING AREA	Illuminance	Fc	1.51	5.7	0.1	15.10
PARKING LOT	Illuminance	Fc	1.74	11.1	0.0	N.A.
SPILL LIGHT	Illuminance	Fc	0.02	8.5	0.0	N.A.

**PHOTOMETRIC STUDY BASED ON ASSUMPTIONS PROVIDED BY DESIGN TEAM
 **IF REFLECTANCE VALUES ARE NOT PROVIDED, STANDARD VALUES ARE ASSUMED (80/50/20)

PROJECT: LOVELL ACADEMY
 LOCATION: ROCKLAND, MA

DRAWN BY: SDP
 DATE: 08/22/21
 NOTES:

SCALE: NTS

